



## CERTIFICATE OF ANALYSIS

**Customer :** PARS Environmental  
500 Horizon Drive, Suite 540  
Robbinsville Twp, NJ 08691

**Project ID :** Warren County Technical, 1500 NJ-57, Washington  
**PAS Project ID :** P21-13683

**Matrix :** Drinking Water  
**Report Date :** 1/7/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-13683-01	WCT-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:30	1/3/22 10:56
P21-13683-02	WCT-1-H Gym-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:30	1/3/22 11:00
P21-13683-03	WCT-1-H 374-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:31	1/3/22 11:24
P21-13683-04	WCT-1-H 374-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:31	1/3/22 11:28
P21-13683-05	WCT-1-388-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:32	1/3/22 11:32
P21-13683-06	WCT-1-388-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:32	1/3/22 11:36
P21-13683-07	WCT-1-388-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:33	1/3/22 11:40
P21-13683-08	WCT-1-387-CF-P	Lead	1.83 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:33	1/3/22 11:44
P21-13683-09	WCT-1-387-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:34	1/3/22 11:48
P21-13683-10	WCT-1-386-CF1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:35	1/3/22 11:52
P21-13683-11	WCT-1-386-CF2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:35	1/3/22 11:56
P21-13683-12	WCT-1-386-CF3-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:36	1/3/22 12:08
P21-13683-13	WCT-1-H 379-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:37	1/3/22 12:12
P21-13683-14	WCT-1-H 379-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:38	1/3/22 12:16
P21-13683-15	WCT-1-382-CF1-P	Lead	1.43 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:39	1/3/22 12:21
P21-13683-16	WCT-1-382-CF2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:40	1/3/22 12:25
P21-13683-17	WCT-1-373-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:41	1/3/22 12:29
P21-13683-18	WCT-1-250-CF1-P	Lead	3.03	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:42	1/3/22 12:33
P21-13683-19	WCT-1-250-CF2-P	Lead	2.83	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:42	1/3/22 12:37
P21-13683-20	WCT-1-245B-CF1-P	Lead	1.83 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:43	1/3/22 12:41
P21-13683-21	WCT-1-245B-CF2-P	Lead	1.83 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:43	1/3/22 12:53
P21-13683-22	WCT-1-246-CF1-P	Lead	1.03 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:44	1/3/22 13:09
P21-13683-23	WCT-1-246-CF2-P	Lead	1.63 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:44	1/3/22 13:13

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



### CERTIFICATE OF ANALYSIS

**Customer :** PARS Environmental  
500 Horizon Drive, Suite 540  
Robbinsville Twp, NJ 08691

**Project ID :** Warren County Technical, 1500 NJ-57, Washington  
**PAS Project ID :** P21-13683

**Matrix :** Drinking Water  
**Report Date :** 1/7/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-13683-24	WCT-1-248-CF1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:45	1/3/22 13:17
P21-13683-25	WCT-1-248-CF2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:45	1/3/22 13:21
P21-13683-26	WCT-1-248-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:46	1/3/22 13:25
P21-13683-27	WCT-1-247-CF1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:46	1/3/22 13:37
P21-13683-28	WCT-1-247-CF2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:47	1/3/22 13:41
P21-13683-29	WCT-1-Cafe-FP1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:50	1/3/22 13:45
P21-13683-30	WCT-1-Kit-FP2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:51	1/3/22 13:49
P21-13683-31	WCT-1-Kit-FP3-P	Lead	3.23	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:52	1/3/22 13:53
P21-13683-32	WCT-1-Kit-FP4-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:53	1/3/22 13:57
P21-13683-33	WCT-1-Kit-FP5-P	Lead	6.44	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:54	1/3/22 14:01
P21-13683-34	WCT-1-Kit-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:55	1/3/22 14:05
P21-13683-35	WCT-1-Kit-ST-P	Lead	25.3	ug/L	2	4.00	1.80	15.0 *	SM 3113 B	12/29/21 08:56	1/3/22 16:42
P21-13683-36	WCT-1-Kit-SP-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:57	1/3/22 14:31
P21-13683-37	WCT-1-Serving-FP6-P	Lead	10.1	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:57	1/3/22 14:35
P21-13683-38	WCT-1-Cafeteria-WC1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:58	1/3/22 14:39
P21-13683-39	WCT-1-Cafeteria-BT1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 08:59	1/3/22 14:43
P21-13683-40	WCT-1-Cafeteria-WC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 09:00	1/3/22 14:47
P21-13683-41	WCT-1-Cafeteria-BT2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 09:01	1/3/22 14:51
P21-13683-42	WCT-1-102-CF1-P	Lead	2.23	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 09:02	1/3/22 15:16
P21-13683-43	WCT-1-102-CF2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 09:03	1/3/22 15:20
P21-13683-44	WCT-1-MO-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 09:04	1/3/22 15:24
P21-13683-45	WCT-1-H MO-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 09:05	1/3/22 15:28
P21-13683-46	WCT-1-Nurse-NS-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/29/21 09:10	1/3/22 15:33

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



**CHAIN OF CUSTODY**

PROJECT ID# 1195-02

**Customer:** PARS Environmental  
**Address:** 500 Horizon Drive, Suite 540  
 Robbinsville, NJ 08691  
**Phone:** (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

**School Name:** Warren County Technical  
**School Address:** 1500 NJ-57, Washington  
**Sampled By:** Marissa Weinstein  
**Print Name:** Marissa Weinstein  
**RESULTS TO:** JPerrini@montrose-env.com

Sample ID	Location	Date: 12/29/21 Time Sampled	Matrix Code	Grab or Comp	Flash Sample	Fiber Present	# Container	Glass or Plastic	Analysis	LAB ID
1	WCT-Field Blank	8:30	DW	Grab	N	N	1	250 ml Plastic	Lead	P21-13683-01
2	WCT-1-H GYM-BT-P	8:30	DW	Grab	N	N	1	250 ml Plastic	Lead	-02
3	WCT-1-H 374-WC-P	8:31	DW	Grab	N	N	1	250 ml Plastic	Lead	-03
4	WCT-1-H 374-BT-P	8:31	DW	Grab	N	N	1	250 ml Plastic	Lead	-04
5	WCT-1-388-IM-P	8:32	DW	Grab	N	N	1	250 ml Plastic	Lead	-05
6	WCT-1-388-BT-P	8:32	DW	Grab	N	N	1	250 ml Plastic	Lead	-06
7	WCT-1-388-WC-P	8:33	DW	Grab	N	N	1	250 ml Plastic	Lead	-07
8	WCT-1-387-CF-P	8:33	DW	Grab	N	N	1	250 ml Plastic	Lead	-08
9	WCT-1-387-WC-P	8:34	DW	Grab	N	N	1	250 ml Plastic	Lead	-09
10	WCT-1-386-CF1-P	8:35	DW	Grab	N	N	1	250 ml Plastic	Lead	-10
11	WCT-1-386-CF2-P	8:35	DW	Grab	N	N	1	250 ml Plastic	Lead	-11
12	WCT-1-386-CF3-P	8:36	DW	Grab	N	N	1	250 ml Plastic	Lead	-12
13	WCT-1-H 379-WC-P	8:37	DW	Grab	N	N	1	250 ml Plastic	Lead	-13
14	WCT-1-H 379-BT-P	8:38	DW	Grab	N	N	1	250 ml Plastic	Lead	-14
15	WCT-1-382-CF1-P	8:39	DW	Grab	N	N	1	250 ml Plastic	Lead	P21-13683-15

SAMPLES REC'D PRESERVED WITH HNO<sub>3</sub>

Page 1 of 4 Deliverables: PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved w/ HNO<sub>3</sub>

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATION CODES:** 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Marissa Weinstein	Marissa Weinstein		12/29/2021
Received:	Lynn Souza	Lynn Souza	PAS	13:15
Relinquished:				
Received:				
Relinquished:				
Received:				



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08785 PHONE 732-814-1515 FAX 732-814-1518

# CHAIN OF CUSTODY

Customer: **PARS Environmental**  
 Address: **500 Horizon Drive, Suite 540**  
**Robbinsville, NJ 08691**  
 Phone: **(609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini**

School Name: **Warren County Technical**  
 School Address: **1500 NJ-57, Washington**  
 Sampled By: **Marissa Weinstein**  
 Print Name: **Marissa Weinstein**  
 RESULTS TO: **JPerrini@montrose-env.com**

Sample ID	Location	Date/Time Sampled	Matrix Code	Grab or Comp	Flash Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
16	WCT-1-382-CF2-P	8:40	DW	Grab	N	N	1	250 ml Plastic	Lead	
17	WCT-1-373-TL-P	8:41	DW	Grab	N	N	1	250 ml Plastic	Lead	P21-13683-16
18	WCT-1-250-CF1-P	8:42	DW	Grab	N	N	1	250 ml Plastic	Lead	-17
19	WCT-1-250-CF2-P	8:42	DW	Grab	N	N	1	250 ml Plastic	Lead	-18
20	WCT-1-245B-CF1-P	8:43	DW	Grab	N	N	1	250 ml Plastic	Lead	-19
21	WCT-1-245B-CF2-P	8:43	DW	Grab	N	N	1	250 ml Plastic	Lead	-20
22	WCT-1-246-CF1-P	8:44	DW	Grab	N	N	1	250 ml Plastic	Lead	-21
23	WCT-1-246-CF2-P	8:44	DW	Grab	N	N	1	250 ml Plastic	Lead	-22
24	WCT-1-248-CF1-P	8:45	DW	Grab	N	N	1	250 ml Plastic	Lead	-23
25	WCT-1-248-CF2-P	8:45	DW	Grab	N	N	1	250 ml Plastic	Lead	-24
26	WCT-1-248-WC-P	8:46	DW	Grab	N	N	1	250 ml Plastic	Lead	-25
27	WCT-1-247-CF1-P	8:46	DW	Grab	N	N	1	250 ml Plastic	Lead	-26
28	WCT-1-247-CF2-P	8:47	DW	Grab	N	N	1	250 ml Plastic	Lead	-27
29	WCT-1-CAFE-FP1-P	8:50	DW	Grab	N	N	1	250 ml Plastic	Lead	-28
30	WCT-1-KIT-FP2-P	8:51	DW	Grab	N	N	1	250 ml Plastic	Lead	-29
										P21-13683-30

SAMPLES REC'D PRESERVED WITH HNO<sub>3</sub>

Page 2 of 4

Deliverables: PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved with HNO<sub>3</sub>: \_\_\_\_\_

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATION CODES:** 0 = Ice 1 = HCl  
 2 = H2SO4 3 = NaOH  
 4 = HNO3 5 = Other

	Print Name	Signature	Company	Date + Time
Relinquished:	Marissa Weinstein	Marissa Weinstein		12/29/2021
Received:	Lynn Souza	Lynn Souza	PARS	13:15
Relinquished:				
Received:				
Relinquished:				
Received:				





**CHAIN OF CUSTODY**

**Customer:** PARS Environmental  
**Address:** 500 Horizon Drive, Suite 540  
 Robbinsville, NJ 08691  
**Phone:** (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

**School Name:** Warren County Tech  
**School Address:** 1500 NT-57, Washington  
**Sampled By:** Marissa Weinstein  
**Print Name:** Marissa Weinstein  
**RESULTS TO:** JPerrini@montrose-env.com

Sample ID	Location	Date/Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Preserv	# Containers	Glass or Plastic	Analysis	LAB ID
31	WCT-1-KIT-FP3-P	8:52	DW	Grab	N	N	1	250 ml Plastic	Lead	P21-13683-31
32	WCT-1-KIT-FP4-P	8:53	DW	Grab	N	N	1	250 ml Plastic	Lead	-32
33	WCT-1-KIT-FP5-P	8:54	DW	Grab	N	N	1	250 ml Plastic	Lead	-33
34	WCT-1-KIT-IM-P	8:55	DW	Grab	N	N	1	250 ml Plastic	Lead	-34
35	WCT-1-KIT-ST-P	8:56	DW	Grab	N	N	1	250 ml Plastic	Lead	-35
36	WCT-1-KIT-SP-P	8:57	DW	Grab	N	N	1	250 ml Plastic	Lead	-36
37	WCT-1-SERVING-FP6-P	8:57	DW	Grab	N	N	1	250 ml Plastic	Lead	-37
38	WCT-1-CAFETERIA-WC1-P	8:58	DW	Grab	N	N	1	250 ml Plastic	Lead	-38
39	WCT-1-CAFETERIA-BT1-P	8:59	DW	Grab	N	N	1	250 ml Plastic	Lead	-39
40	WCT-1-CAFETERIA-WC2-P	9:00	DW	Grab	N	N	1	250 ml Plastic	Lead	-40
41	WCT-1-CAFETERIA-BT2-P	9:01	DW	Grab	N	N	1	250 ml Plastic	Lead	-41
42	WCT-1-102-CF1-P	9:02	DW	Grab	N	N	1	250 ml Plastic	Lead	-42
43	WCT-1-102-CF2-P	9:03	DW	Grab	N	N	1	250 ml Plastic	Lead	-43
44	WCT-1-MO-TL-P	9:04	DW	Grab	N	N	1	250 ml Plastic	Lead	-44
45	WCT-1-HMO-BT-P	9:05	DW	Grab	N	N	1	250 ml Plastic	Lead	P21-13683-45

SAMPLES REC'D PRESERVED WITH HNO<sub>3</sub> (2)

PDF Std.  PDF Reduce  PDF Full  EDD

Page 3 of 4

Deliverables:

Date/Time Preserved with HNO<sub>3</sub>:

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATIVE CODES:** 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Marissa Weinstein	Marissa Weinstein		12/29/2021
Received:	Lynn Souza	Lynn Souza	PAS	13:15
Relinquished:				
Received:				
Relinquished:				
Received:				

